


**ELECTRIC FLUSH VALVE #1 WIRING**  
 Red: R/+ (Left)  
 Black: R (Right)  
 White: 1

REVISIONS				
REV	ZONE	DESCRIPTION	DATE	APPROVED
1	2C, 4C	MOVED ALARM STANDBY VALVE FROM INLET TO OUTLET OF FILTER.	01/16/15	S.P.

**GB7 ELECTRIC CONTROLLER**



**ELECTRIC ALARM STANDBY WIRING:**  
 Red: R/+ (Left)  
 Black: R (Right)  
 White: A

**ELECTRIC FLUSH VALVE #2 WIRING**  
 Red: R/+ (Left)  
 Black: R (Right)  
 White: 2

-----	Electrical Connection
=====	Hydraulic Connection
○	Junction
)	No Junction

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOLERANCES		AUTOMATIC FILTERS, INC. 2672 S. LA CIENEGA BLVD. LOS ANGELES, CA 90034 (310) 839-2828 FAX (310) 839-6878		
DECIMALS .XX ± .05 .XXX ± .01		TITLE 2 ABW FILTERS IN PARALLEL W/ GB7 ELECTRIC CONTROLLER, ELECTRIC FLUSH VALVES, & ELECTRIC ALARM STANDBY VALVE		
DRAWN S. PERKINSON	DATE 07/06/12	SIZE A	DWG NO. WIRE-2ABWGB7-EFV-EBV-LAY-02	REV 1
CHECKED		NOT TO SCALE		SHEET 1 OF 1